

FIRE SAFETY CERTIFICATE

No. RC NO. 01/A2/2022 | Dated 04-11-2022

Dated : 28.06.2024

RF NO. 01/A2/2024 | Dated 04-11-2024

Certified that the **Navyabharathi Educational Society** at **Perkit Village (V), Armoor (M), Nizamabad Dist** comprised of **Zero basement(s)** and **Ground + 1 floors** (upper floors) occupied by **Navyabharathi Educational Society, Hyderabad** have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 27.06.2024 (date of inspection) in the presence of **K. Santhosh Kumar** plot no: **408, Navyasri Homes, armur Road, Nizamabad** and that the building/ premises is fit for occupancy upto classes **XII** With effect from 27.06.2024 for a period of **Five** years in accordance with rule and subject to compliance of specific conditions as appended:-

1. **N A**
2. **N A**
3. **N A**
4. **N A**

Issued on 28.06.2024 at Nizamabad by

Signature with Seal:
 Name :
 Designation :
 Name & Address of Department/ Office:

 G. Murali Mohan Reddy
 District Fire Officer
 Nizamabad District

To
Navyabharathi Educational Society
H.No 4.167,
Manikbhandar(V), Makloor(M),
Nizamabad Dist

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to
 (reasons to be recorded).

(Name and designation of the authorized signatory)

APPENDIX - XII

FIRE SAFETY CERTIFICATE

No. RC N 0.01 / A2/2022 / Dated 04-11-2022

Dated: 04-11-2022

Certified that the Navyabharathi School, H.No. 1-124/1, Perkit Village (V), Armoor (M), Nizamabad Dist comprised of Zero basement(s) and Ground + 1 floors (upper floors) occupied by Navyabharathi Educational Society, Hyderabad have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 04-11-2022 (date of inspection) in the presence of K. Santhosh Kumar plot no: 408, Navyasti Homes, Armoor Road, Nizamabad and that the building/ premises is fit for occupancy upto classes XII With effect from 04-11-2022 for a period of Five years in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on _____ at Nizamabad by

Signature with Seal:
Name:
Designation: (C. M. All Member, H. S. C.)
Name & Address of Department/ Office: D. M. C. Fire Officer, Nizamabad Division

To
Navyabharathi Educational Society
H.No 4.167,
Manikbhandar(V), Makdoor(M),
Nizamabad Dist

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded)

(Name and designation of the authorized signatory)

Correspondent
Navyabharathi School
Perkit, Armoor.

ANNEXURE - I

(Annexure to G.O.MS.No.56, Home (Ser.IV) Department, Dated: 26.7.2019)

Instructions to be followed for schools existing before 13.04.2009.

Self Certification of Fire Safety Measures by School Management:-

I) General Information for School Buildings of all categories i.e., A,B,C,D.

SL. NO	DETAILS	
1.	Date of the opening of the school building	09-06-2003
2.	Name of the applicant	K. Santhosh Kumar
3.	Name and address of the School	Navya Bharathi School, H. No. 1-124/1, Perkit (V), Armoor (M), Nizamabad (Dist).
4.	Telephone Number and email of the applicant	9666664494, santhosh.wildlife@gmail.com
5.	Height of the building (in meters)	6.00 meters
6.	No of floors	Ground Floor +1 Upper Floor
7.	Abutting Road width (in meters)	9 mtrs
8.	Built – up area of each floor in Sq.mtrs Ground _____ Floor1 _____	Ground Floor – 862.00 Sq.mts First Floor – 740.00 Sq.mts.
9.	Number of staircases Staircases 1 _____ (width in meters) Staircases2 _____ (width in meters)	Stair case – 02 No.s
10.	Width of each Staircase	1.00 mt
11.	Open Spaces Front _____ (width in meters) Side 1 _____ (width in meters) Side 2 _____ (width in meters) Rear _____ (width in meters)	East – 33' 0' wide road West – 1.0 mtrs North – 650 mtrs South – 3.0 mtrs



Signature with date of
Correspondent
School authority and seal
Navyabharathi School
Perkit, Armoor.

A) School Building with Ground Floor (or) Ground plus one upper floor:-

Sl No	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided
				Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 Liters water expelling extinguishers or ABC 4 kgs Fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius.	08 No's	08 No's
2	Automatic Sprinkler System (IS 15105:2002). The IS Standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area of basement exceeds 200 square meters	NA	NA

Note: For Ground+1 Floor buildings, if the floor area in a single floor is more than 500 square meters and if there is only single stair case, a second stair case of 1.50 meters width shall be Provided with concrete/Metal Steel Structure.



Signature with date of
Correspondent
Navyabharathi School
 Perkit, Armoor.



II) General Fire Safety Measures which should be followed by all schools:-

SL.NO	General Fire Safety measures	Whether followed Yes/No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or other combustible materials.	Yes
2	It should be ensured that the available fire safety equipment is always in good working condition.	Yes
3	Preschool kinder garden and class/grade 1 students shall be located on ground /level of exit discharge and class/grade 2 students shall be located not above one floor higher than ground floor/level exit discharge.	Yes
4	Kitchen should be constructed /provided away from the school building.	Yes
5	All school shall prepare an evacuation plan in consultation with local fire officer.	Yes
6	All teacher/employees should be trained in operating the available fire safety equipment in the building.	Yes
7	All exits/escape routes shall be kept free from any obstructions for free passage in case of any emergency.	Yes
8	All the internal stair cases lifts, lobbies and corridors should be adequately ventilated and illuminated.	Yes
9	If the school is provided with central air-conditioning system, all safety measures as per clause 10.1 of IS 14435:1997S should be followed.	Yes
10	School building shall be kept free from inflammable and toxic material. if storage is inevitable, they should be stored safety.	Yes
11	Any hazardous/ combustible material/volatile flammable liquids shall not be stored in school building.	Yes
12	Dos and Donts in case of fire /emergency shall properly displayed at strategic locations of the building.	Yes
13	Auto glow sign boarders shall be provided indicating exits/escape routes.	Yes
14	Electric wiring in the entire building shall be checked and certified by the competent authority.	Yes
15	Structural stability of the building shall be checked and certified by the competent authority.	Yes
16	Public address system shall be provided for use in case of any emergency and this system shall cover the entire building.	Yes
17	Detailed information regarding the number of teacher /employees working shall be displayed at strategic locations of the building.	Yes
18	Display all emergency supporting numbers such as nearest fire stations hospitals/ ambulances etc. on the floor and at strategic locations.	Yes

19	A pictorial map with details of entries /exits, details of class rooms/laboratories staff rooms and open place(assembly point)of the school building shall be prepared and displayed in strategic locations.	Yes
20	If basement area of the building exceeds 200 square meters, required to provide automatic sprinkler system as per IS 15105:2002	No

We Navya Bharathi School, H. No. 1-124/1, Perkit (V), Armoor (M) of Nizamabad District management/respondent hear by certify that the information furnished is correct and if it is notices at any time that the information provided is false, we understand that our school affiliation may be canceled by the concerned authority. We have installed fire safety measures as per Annexure-I and undertake to maintain the same in good working condition at all times.



Signature with date of
School authority and seal
Name and designation
Correspondent
Navyabharathi School
Perkit, Armoor.

Copy received in Annexure -I, The school management is here by installed to maintain fire safety measures as per the G.O.Ms.No.56, Dated:26-07-2019 of the HOME (SERVICES-IV) DEPARTMENT.


District Fire Officer
Nizamabad.